

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7271-0065:136 Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: Faraday Inc, 805 South Maumee St., Tecumseh MI 49286
Contact: Steve A. Blohm (517) 423-2111

DESIGN: Models 8900, 8902, 8904, 8901, 8903 series with Model 8914 base. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as ionization smoke detectors for use with separately listed compatible fire alarm control units. Model 8904 is intended for use with Model 8930 duct detector base (CSFM Listing No. 3240-0065:140).

XLF: 7271-0067:101

02-29-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **SEPTEMBER 10, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager